

**2023 Annual Drinking Water Quality Report
Town of Greenville
PWS #2400440**

**We are pleased to report that our drinking water meets
all federal and state requirements.**

This report shows our water quality results and what they mean.

We're pleased to present to you this year's Annual Drinking Water Quality Report. This report is designed to inform you about the quality water and services we deliver to you every day. Our constant goal is to provide you with a safe and dependable supply of drinking water. We want you to understand the efforts we make to continually improve the water treatment process and protect our water resources. We are committed to ensuring the quality of your water. Our water source is ground water from two wells. The wells draw from the Floridan Aquifer. The water is then chlorinated for disinfection purposes, aerated for odor control, then polyphosphates are added for iron removal.

In 2023, the Florida Department of Environmental Protection (DEP) performed a Source Water Assessment on our system. The assessment was conducted to provide information about any potential sources of contamination in the vicinity of our wells. There are three potential sources of contamination identified for this system with a low to high susceptibility level. The assessment results are available on the DEP Source Water Assessment and Protection Program (SWAPP) website at <https://prodapps.dep.state.fl.us/swapp/> or they can be obtained from Wayne Malone at 850-869-9908.

If you have any questions about this report or concerning your water utility, please contact City Hall at 850-948-2251 between 8 AM and 3 PM to address the customer's questions. We encourage our valued customers to be informed about their water utility. This report will be mailed to customers only upon request and is also available at City Hall.

The Town of Greenville routinely monitors for contaminants in your drinking water according to federal and state laws, rules, and regulations. Except where indicated otherwise, this report is based on the results of our monitoring for the period of January 1 to December 31, 2023. Data obtained before January 1, 2023, and presented in this report is from the most recent testing done in accordance with the laws, rules, and regulations.

In the table below, you may find unfamiliar terms and abbreviations. To help you better understand these terms we've provided the following definitions:

Maximum Contaminant Level or MCL: *The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.*

Maximum Contaminant Level Goal or MCLG: *The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.*

Action Level (AL): *The concentration of a contaminant which, if exceeded, triggers treatment or other requirements that a water system must follow.*

Maximum residual disinfectant level or MRDL: *The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.*

Maximum residual disinfectant level goal or MRDLG: *The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to*

control microbial contaminants.

ND: means not detected and indicates that the substance was not found by laboratory analysis

Parts per billion (ppb) or micrograms per liter (ug/l): One part by weight of analyte to 1 billion parts by weight of the water sample.

Parts per million (ppm) or milligrams per liter (mg/l): One part by weight of analyte to 1 million parts by weight of the water sample.

Inorganic Contaminants

Contaminant and Unit of Measurement	Dates of sampling (mo/yr)	MCL Violation Y/N	Level Detected	Range of Results	MCLG	MCL	Likely Source of Contamination
Sodium (ppm)	09/2023	N	4.1	N/A	N/A	160	Saltwater intrusion, leaching from soil
Barium (ppm)	09/2023	N	0.0039	N/A	2	2	Discharge of drilling wastes; discharge from metal refineries; erosion of natural deposits
Chromium (ppb)	09/2023	N	2.0	N/A	100	100	Discharge from steel and pulp mills; erosion of natural deposits

Synthetic Organic Contaminants including Pesticides and Herbicides

Contaminant and Unit of Measurement	Dates of sampling (mo/yr)	MCL Violation Y/N	Level Detected	Range of Results	MCLG	MCL	Likely Source of Contamination
Oxamyl [Vydate] (ppb)	09/2023	N	1.7	N/A	200	200	Runoff/ leaching from insecticide used on apples, potatoes, and tomatoes
Dalapon (ppb)	09/2023	N	0.34	N/A	200	200	Runoff from herbicide used on rights of way
Benzo(a)pyrene (PAH) (nanograms/l)	09/2023	N	88.0	N/A	0	200	Leaching from linings of water storage tanks and distribution lines

Secondary Contaminants

Contaminant and Unit of Measurement	Dates of sampling (mo/yr)	MCL Violation Y/N	Level Detected	Range of Results	MCLG	MCL	Likely Source of Contamination
Total Dissolved Solids (ppm)	09/2023	Y	2500	N/A	N/A	500	Natural occurrence from soil leaching
Chloride (ppm)	09/2023	N	9.0	N/A	N/A	250	Natural occurrence from soil leaching
Iron (ppm)	09/2023	Y	0.42	N/A	N/A	0.3	Natural occurrence from soil leaching
Manganese (ppm)	09/2023	N	0.024	N/A	N/A	0.05	Natural occurrence from soil leaching
Zinc (ppm)	09/2023	N	0.0036	N/A	N/A	5	Natural occurrence from soil leaching

Contaminant and Unit of Measurement	Dates of sampling (mo/yr)	MCL Violation Y/N	Level Detected	Range of Results	MCLG	MCL	Likely Source of Contamination
Copper (ppm)	09/2023	N	0.0018	N/A	N/A	1	Corrosion byproduct and natural occurrence from soil leaching

Stage 1 and Stage 2 Disinfectants and Disinfection By-Products

Contaminant and Unit of Measurement	Dates of sampling (mo/yr)	MCL or MRDL Violation Y/N	Level Detected	Range of Results	MCLG or MRDLG	MCL or MRDL	Likely Source of Contamination
Chlorine (ppm)	Monthly 2023	N	1.11	0.3 – 2.14	MRDLG = 4	MRDL = 4.0	Water additive used to control microbes
Total Trihalomethanes (TTHM) (ppb)	09/2023	N	62	N/A	N/A	80	By-product of drinking water disinfection
Haloacetic Acids (HAA5) (ppb)	09/2023	N	20.41	N/A	N/A	60	By-product of drinking water disinfection

Lead and Copper (Tap Water)

Contaminant and Unit of Measurement	Dates of sampling (mo/yr)	AL Exceeded (Y/N)	90 th Percentile Result	No. of sampling sites exceeding the AL	MCLG	AL (Action Level)	Likely Source of Contamination
Copper (tap water) (ppm)	06/2022	N	0.055	0 of 10	1.3	1.3	Corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives
Lead (tap water) (ppb)	06/2022	N	3.2	0 of 10	0	15	Corrosion of household plumbing systems; erosion of natural deposits

During June through September 2023, we were required to collect twenty tap samples for Lead and Copper. These samples were not taken. Beginning in 2024, twenty tap samples will be required to collect every six months for at least two six-month periods.

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. (insert name of utility) is responsible for providing high quality drinking water but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to two minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>.

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing

chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. U.S. Environmental Protection Agency/Center for Disease Control guidelines on appropriate means to lessen the risk of infection by Cryptosporidium and other microbiological contaminants are available from the Safe Drinking Water Hotline (800-426-4791).

Contaminants that may be present in source water include:

- (A) Microbial contaminants, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.*
- (B) Inorganic contaminants, such as salts and metals, which can be naturally occurring or result from urban stormwater runoff, industrial or domestic wastewater discharges, oil and gas production, mining or farming.*
- (C) Pesticides and herbicides, which may come from a variety of sources such as agriculture, urban stormwater runoff and residential uses.*
- (D) Organic chemical contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations, urban stormwater runoff, and septic systems.*
- (E) Radioactive contaminants, which can be naturally occurring or be the result of oil and gas production and mining activities.*

To ensure that tap water is safe to drink, the EPA prescribes regulations, which limit the amount of certain contaminants in water provided by public water systems. The U.S. Food and Drug Administration (FDA) regulations establish limits for contaminants in bottled water, which must provide the same protection for public health.

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline at 1-800-426-4791.

We at the Town of Greenville would like you to understand the efforts we make to continually improve the water treatment process and protect our water resources. We are committed to ensuring the quality of your water. If you have any questions or concerns about the information provided, please feel free to call any of the numbers listed.

Please DO NOT FLUSH your unused/unwanted medications down toilets or sink drains. More information is available at <http://www.dep.state.fl.us/waste/categories/medications/pages/disposal.htm>.